

BRILLIANT KIDS GLOBAL SCHOOL
FORM-C

Form of Certificate of structural soundness under sub-section (4) of Section 4 of the Tamil Nadu Public Building (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in Rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules 1966

I certify that I have inspected the Building mentioned in the statement and furnished its salient technical features.

1. Foundation:-

- | | |
|--|------------------|
| i. Depth below ground level | :- 4 m |
| ii. Nature of soil set out in the Foundation Level. | :- Kankar |
| iii. Pressure at foundation | :- 23Tonnes/Sqm |
| iv. Probable safe bearing capacity of the statement with at Foundation | :- 30 Tonnes/Sqm |

2. Superstructure:-

- | | |
|--|---|
| i. Maximum stress in the most Critical section of masonry and Concrete | R.C.C.Column – 25 kg / sqcm
:- Brick masonry - 8 t / Sq.m |
| ii. Nature of masonry and concrete Its safe permissible stress | R.C.C.Column – 50 kg / sqcm
:- Brick masonry - 40 t / Sq.m |

The structural soundness of the building has been verified by me with reference to ISI loading standard 875 (Latest version) and other relevant Indian Standard Code of practices and I declare that the buildings are structurally sound to be used as a Public Building for the purpose noted in the statement.

A license may be granted for the period from 01-02-2023 to 31-01-2026.

Place:- Palani

Date:- 25-01-2023


Collector's Panel Engineer

E. K. SELVARAJ, B.E., M.I.E., F.I.V., DACAD., D. Asst.,
Chartered Civil Engineer (M/061551/
Approved Valuer (F-9388)
Wealth Tax Valuer of I.T. Dept (1/2010-11)
District Collector's Panel Engineer
IN DTCP No: RE. 26/2019 (Grade II)
SRI BALAJI CONSTRUCTIONS
65, Subramaniapuram Road, Opp: To Samy Theatre,
PALANI-624601. ☎ 99409 81056, 8015473383